

Certified Original Copy

Certificate of Conformity

LOVAG-Certificate No.: FR15-009a

This Certificate applies only to the apparatus verified. The responsibility for conformity of any apparatus having the same designation with that verified rests with the manufacturer or responsible vendor.

This certificate has been prepared according to LOVAG (Low Voltage Agreement Group) Objectives and Operating Principles of mutual recognition. The responsible certification body as a member of LOVAG issues a Certificate of Conformity with the above mentioned Standard(s) following the exclusive use of LOVAG Verification instruction wherever applicable.

Only integral reproduction of this Certificate or reproductions of this page accompanied by any page(s) on which are stated the verifications performed and the assigned rated characteristics of the apparatus verified, are permitted without written permission from the LOVAG Signatory responsible for this Certificate

Apparatus

Remotely operated transfer switching equipment

Designation Type

ATyS, ATyS r, ATyS d, ATyS t, ATyS p, ATyS g : 800 A, 1000 A, 1250 A

Manufacturer

SOCOMEK S.A.
1 - 4 Route de Westhouse – B.P. 60010
67235 BENFELD Cedex - France

Applicant:

SOCOMEK S.A.
1 Route de Westhouse – B.P. 60010
67235 BENFELD Cedex - France

Verified by:

ASEFA platform H01
The apparatus, constructed in accordance with the description mentioned in the Report listed in this Certificate has been subjected to the series of proving verifications in accordance with IEC 60947-6-1 (2013) Edition 3.1, EN 60947-6-1 (2006) + A1 (2014): Test sequence II

The results are shown in the Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristics assigned by the manufacturer as stated below

| | | | |
|--|--|--------------------------------------|--------------------------------------|
| Classification | Class PC | | |
| Rated operational voltage, U_e | 415 V a.c. | Insulation voltage, U_i | 1000 V |
| Frequency | 50 / 60 Hz | Impulse withstand voltage, U_{imp} | 12 kV |
| ATyS , ATyS r/d/t/p/g | 800 A | 1000 A | 1250 A |
| Rated thermal current, I_{th} , I_{the} | 800 A | 1000 A | 1250 A |
| Utilization category | AC-32B (I_e / U_e): / AC-33B (I_e / U_e): 800 A / 415 V ~ | / 1000 A / 415 V ~ | 1250 A / 415 V ~ 1000 A / 415 V ~ |
| Other characteristics are given in the Test Report mentioned below | | | |

This document includes Test Report No.: H01.15.09
Issue Date: 2015-01-15

Responsible Certification Body:



Accréditation n° 5-0037
Portée disponible sur / Scope
available on www.cofrac.fr

ASEFA
33, avenue du Général Leclerc
92260 Fontenay-aux-Roses
France

Marie-Elisabeth d'ORNANO

po. Vincent SCHUHL
Authorized Signature
Date : 2015-06-01

