

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Control switch

Name and address of the applicant

SOCOMECS.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMECS.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

SOCOMECS.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ui:690V;Uimp:8kV(FMD 30 HIGH RANGE AC380-690V), 6kV(FMD 30 LOW RANGE AC120-260V); AC-15:Ue/Ie:AC250V/1A;DC-13:Ue/Ie:DC24V/0.2A; Ith:1A(Relay output);IP20

Trademark / Brand (if any)

SOCOMECS

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

FMD 30;

Additional information (if necessary may also be reported on page 2)

IEC 60947-5-1:2016(4th Edition)

A sample of the product was tested and found to be in conformity with

00901-CB2021CQC-098025

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE


Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Sep.22,2021

Signature:



Xie ZhaoXu