



Certificate of Compliance

Certificate: 1297273

Master Contract: 189705 (112964)

Project: 70107185

Date Issued: 2017-09-11

Issued to: Socomec S.A.
rue de Westhouse 1
BP 10
Benfeld Cedex, 67235
FRANCE

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Patrick Quinty*
Patrick Quinty

PRODUCTS

CLASS - C465102 - SWITCHES-Dead-front (Open Type)

Fused load break switches and non-fused load break switches, open type, for use in industrial control equipment, 600V ac and less, 250V dc certified as disconnecting switches unless noted otherwise (*).

Part A Non-fusible switches, visible contact, Series SIRCO V followed by 60 A, 100 A or 200 A, rated 200kA at 600Vac and 100kA at 250Vdc.

Reference	Cat. No. 3 pole	4 pole
SIRCO V 100A	27053010	27054010
SIRCO V 60A	27053006	27054006
SIRCO V 200A	27053020	27054020

Part B Fusible switches, Series FUSERBLOC followed by J 30 A, J 60 A, J 100 A or J 200 A, rated 200kA at 600Vac and 100kA at 250Vdc.

Reference	Cat. No. 3 pole	4pole
FUSERBLOC J 100A	37163010	37166010
FUSERBLOC J 100A without test position	-----	-----
FUSERBLOC J 200A	37163020	37166020



Certificate: 1297273
Project: 70107185

Master Contract: 189705
Date Issued: 2017-09-11

FUSERBLOC J 200A without test position	-----	-----
FUSERBLOC J 30A	37163004	37166004
FUSERBLOC J 30A without test position	-----	-----
FUSERBLOC J 60A	37163006	37166006
FUSERBLOC J 60A without test position	-----	-----

Fusible switches, Series FUSERBLOC followed by CC 30 A, J 30 A, rated 100kA at 600Vac and 100kA at 250Vdc.

Reference	Cat. No. 3 pole	4pole
FUSERBLOC CC 30A	37163003	37166003
FUSERBLOC CC 30A without test position	-----	-----
FUSERBLOC 30A CC 2P side, 2 pole	Cat. No. 2 pole:	37162003
FUSERBLOC J 30A	37163005	37166005
FUSERBLOC J 30A without test position	-----	-----

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 4-16 - Enclosed Switches



Supplement to Certificate of Compliance

Certificate: 1297273

Master Contract: 189705 (112964)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70107185	2017-09-11	Update report as per Notice 17 and 21 (CSA C22.2 No.4-16).
2676040	2014-01-20	Modification of short-circuit rating of 250Vdc at 100kA.
2460088	2011-10-19	Addition of alternate plastic: LA70K by BADA, A3K and A3X2G5 by BASF.
2067204	2008-10-21	Add alternate plastic material.
1902875	2007-04-26	CSA report 1297273 update to add modifications
1825991	2006-11-16	CSA file update, to add new Models and alternative plastic materials.
1699244	2005-12-14	CSA file update, Model Sirco/Fuserbloc.
1520252	2004-05-05	CSA file update - fused load break switches and non-fused load break switches.
History		
1413889 added to description.	2003-06-05	Report update, descriptive of fuserbloc 30A CC 2P Side, 2 pole cat. 37162003
1297273	2002-06-20	Original Edition