

# CERTIFICATE OF PRODUCT CERTIFICATION

## TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2015010302822455

Valid from: Nov.23,2020

Valid until: Jul.20,2031

**NAME AND REGISTERED ADDRESS OF THE APPLICANT** SOCOMEC China Co.,Ltd.  
Unit k, 6/F, No.258 North Fute Road, Pilot Free Trade Zone Shanghai, P.R.China

**NAME AND REGISTERED ADDRESS OF THE MANUFACTURER** SOCOMEC S.A  
1, Rue De Westhouse 67230 Benfeld Cedex France

**NAME AND LOCATION OF THE FACTORY** SOCOMEC S.A  
1, Rue De Westhouse 67230 Benfeld Cedex France

**PRODUCT NAME, MODEL AND SPECIFICATION** Load Switch Disconnecter  
SIRCO 1250A,SIRCO 1600A : Ui : 1000V; Uimp:12kV; Ue: AC415V; Ith: 1250A,1600A; Ie: 1250A,1600A; Icw: 50kA/1s; Icm(Peak): 75kA; Utilization Category: AC-22B; Poles: 6P,8P;

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS** GB/T 14048.3-2017

**TYPE OF CERTIFICATION SCHEMES** Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Apr.10,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGN BY

陈昕

SIGNATURE

陆楠



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0073153



# 产品认证证书


## II型自愿认证

附 录

证书编号: CQC2015010302822455

第 1 页 共 1 页

纸 号: 73153



\*6极或8极负荷隔离  
开关可以通过一个手  
柄实现开关OFF及ON

I.

注: 此附录与证书同时使用时有效。



中国质量认证中心

